

VOC Content Test Certificate

Thursday, August 29th, 2013

Manufacturer: Ardex Australia (7/20 Powers Road, Seven Hills, NSW 2147)

Sample Description: Ardex A30

Date Tested: August 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex A30
Sub-floor Adhesive 50 grams per Litre as VOC content per material	<1 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV130813