

VOC Content Test Certificate

Friday August 29th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex AF545 heavy duty epoxy adhesive

Date Tested: August 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia	Ardex AF545
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
Rubber Flooring Adhesive 60 grams per Litre	45 grams per Litre
Specification	
Green Building Council of Australia	Ardex AF545
Green Star Office Design V3 IEQ-13	
Rubber Flooring Adhesive 60 grams per Litre	45 grams per Litre



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0808-27