

VOC Content Test Certificate

Friday August 29th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex AF545 heavy duty epoxy adhesive

Date Tested: August 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex AF545
Rubber Flooring Adhesive 60 grams per Litre	45 grams per Litre
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex AF545
Rubber Flooring Adhesive 60 grams per Litre	45 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0808-27