



Professional Scientific Solutions

VOC Content Test Certificate

Monday, January 24th, 2011

Manufacturer: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills, NSW, 2147)

Sample Description: AF748 Linoleum Adhesive

Tested: December 2010

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	AF748
Sub-Floor Adhesive 50 grams per Litre as VOC content material	7 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	AF748
Sub-Floor Adhesive 50 grams per Litre as VOC content material	7 grams per Litre as VOC content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1012-06