

VOC Content Test Certificate

Thursday October 6th, 2011

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills NSW 2147)

Sample Description: ARDEX K 301

Date Tested: October 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

| | |
|--|---|
| <p>Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p> | <p>ARDEX K 301</p> |
| <p>One and two pack performance coatings for floors</p> <p>140 grams per Liter as VOC content per material</p> | <p>6 grams per Liter as VOC content per material</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV111002