

VOC Content Test Certificate

Tuesday July 8th, 2008

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: ARDEX K80 self-levelling compound

Date Tested: July 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ -13 Green Star Office Design V3 IEQ-13 Green Star Office Interiors V1.1 IEQ -11	ARDEX K80
Sub-Floor Adhesive 50 grams per Litre	17 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0807-07