

# VOC Content Test Certificate

Tuesday July 8<sup>th</sup>, 2008

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: ARDEX P51 modified PVA primer

Date Tested: July 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Design V3 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>ARDEX P51</b>
Sub-Floor Adhesive 50 grams per Litre	<b>10 grams per Litre</b>



Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ, ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0807-07- CV070402