

# VOC Content Test Certificate

Monday, 25<sup>th</sup> July 2011

Supplier: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex S4

Date Tested: July 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p><b>Specification</b></p> <p><b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Interiors V1.1</b>  <b>IEQ-11</b></p>	<p><b>Ardex S4</b></p>
<p>Architectural Sealant 250 grams per Litre as VOC content material</p>	<p><b>&lt;1 grams per Litre as VOC content material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1106-23