

VOC Content Test Certificate

Tuesday, 4th August 2015

Manufacturer: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147)

Sample Description: BLINDSIDE ARDEX RA 146

Date Tested: August 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	BLINDSIDE ARDEX RA 146
Multipurpose Construction Adhesive 70 grams per Litre as VOC content per material	16 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal
Consultant



Tuan Duong
PhD. BEng (Chemical Engineer)
Consultant



Nick Joy
BSc(Hons)
Consultant

CV150732