

VOC Content Test Certificate

Thursday December 4th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex Abacrete bonding agent for use with screeds and renders

Date Tested: December 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex Abacrete
Architectural Sealant 250 grams per Litre as VOC content material	<10 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex Abacrete
Architectural Sealant 250 grams per Litre as VOC content material	<10 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-34