

# VOC Content Test Certificate

Tuesday April 17<sup>th</sup>, 2007

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Abaflex tile adhesive

Production Date: March 2007

Date Tested: April 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star IEQ-13</b>	<b>Abaflex</b>
Ceramic Tile Adhesive 65 grams per Litre	<b>23 grams per Litre</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant