

VOC Content Test Certificate

Tuesday, 23th February 2016

Manufacturer: Ardex Australia Pty Ltd (20 Powers Road, Seven Hills, NWS, 2147).

Sample Description: Ardex EG 15 Ceramic tile adhesive

Date Tested: February 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification	
Green Building Council of Australia Green Green Star Office Design V2 IEQ-13 Green Star Office Design V1.1 IEQ-11	Ardex EG 15
Ceramic Tile Adhesive, contains reactive diluents 65 grams per Litre as VOC content per material	21 gram per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160216