

VOC Content Test Certificate

Friday April 30th, 2010

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex WJ 50

Date Tested: April 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|---|--|
| Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 | Ardex WJ 50 |
| Ceramic Tile Adhesive 65 grams per Litre as VOC content material | 4 grams per Litre as VOC content per coating |
| Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13 | Ardex WJ 50 |
| Ceramic Tile Adhesive 65 grams per Litre as VOC content material | 4 grams per Litre as VOC content per coating |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 anaging Director and Principal Consultant

1004-13