

VOC Content Test Certificate

Thursday October 16th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road Seven Hills NSW 2147)

Sample Description: Ardex X52 tile adhesive

Date Tested: October 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex X52
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	12 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex X52
Ceramic Tile Adhesive 65 grams per Litre as VOC content material	12 grams per Litre as VOC content per coating



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0810-04