

VOC Content Test Certificate

Tuesday, February 08, 2011

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex WPM 172 Rapid Cure Rubber Waterproofing Membrane

Date Tested: January 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Ardex WPM 172
Architectural Sealant 250 grams per Litre as VOC content material	<1grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex WPM 172
Architectural Sealant 250 grams per Litre as VOC content material	<1 grams per Litre as VOC content material



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F1101-02